

# Hazard Register



<b>Type</b>	FUEL TRAILER	<b>Location</b>	
<b>Make</b>	PETRO INDUSTRIAL	<b>Sale Number</b>	9054058
<b>Model</b>	1250 LTR	<b>Lot Number</b>	0011
<b>Serial Number</b>			

ID	Hazard Type	Hazard Description
142582.1	Controls	ALL OPERATIONAL CONTROLS (VALVES AND PUMPS) TO BE CLEARLY IDENTIFIED AND LABELLED.
142582.2	Electrical	IF ELECTRICAL PUMPS ARE USED ENSURE PLANT IS REGULARLY INSPECTED AND MAINTAINED AS PER AS/NZS 3760: IN-SERVICE SAFETY INSPECTION AND TESTING OF ELECTRICAL EQUIPMENT, AS/NZS 3000: WIRING RULES, AND/OR AS 1543: ELECTRICAL EQUIPMENT OF INDUSTRIAL MACHINES.
142582.3	Signage	ENSURE THAT THE RELEVANT DANGEROUS GOODS CLASSIFICATION IS DISPLAYED ON THE TANK. COMBUSTIBLE LIQUID PLACARD SIGNAGE IS PRESENT ON THIS PLANT.
142582.4	Plant Operation	OPERATOR MUST BE FAMILIAR WITH THE LOCATION AND OPERATION OF THE MAIN ISOLATING SWITCH AND FIRE FIGHTING APPLIANCES/SERVICES.
142582.5	Work Method	ENSURE THAT JSA TAKES INTO CONSIDERATION PERSONAL INJURY EXPOSURES (E.G. MANUAL HANDLING TASKS). IN PARTICULAR ANY COMPONENT OF SIGNIFICANT WEIGHT SHOULD BE MARKED WITH ITS WEIGHT TO WARN THE OPERATOR.
142582.6	Mechanical	POWER SUPPLY TO THE PLANT MUST BE ISOLATED, DENERGISED BEFORE COMMENCING ANY CLEANING AND OR MAINTENANCE ACTIVITIES.
142582.8	Plant Operation	NO SERVICE/MAINTENANCE RECORDS AVAILABLE. REQUIRES REGULAR DOCUMENTED CONDITION INSPECTIONS (INCL SAFETY RELATED CONTROLS).
142582.9	Mechanical	UNATTENDED PLANT SHOULD HAVE POWERED MOTIONS DISABLED AND PLANT ISOLATED BEFORE ANY WORK COMMENCES. ENSURE CONSIDERATION IS GIVEN TO STORED ENERGY INCL: GRAVITATIONAL AND LOADS UNDER SPRING COMPRESSION OR TENSION.
142582.10	Guarding	ENSURE GUARDING PROVIDED TO PREVENT FALL FROM HEIGHTS WHEN WORKING ON TOP OF TANKS (NOT APPLICABLE FOR THIS PLANT). PROVIDE BARRIER (GRID OR MESH BARRIERS) AS PER AS 1657: FIXED PLATFORMS, WALKWAYS, STAIRWAYS AND LADDERS - DESIGN, CONSTRUCTION AND INSTALLATION.
142582.11	Plant Operation	NO OPERATING INSTRUCTIONS AVAILABLE FOR THE PLANT. PROVIDE TRAINING AND ATTACH INSTRUCTIONS IN A CLEAR AND VISIBLE POSITION FOR THE OPERATOR.
142582.12	Electrical	PLANT TO BE USED IN CONJUNCTION WITH EARTH LEAKAGE CIRCUIT BREAKER (SAFETY SWITCH) AND OVERLOAD PROTECTION (IF APPLICABLE).
142582.13	Plant Structure	PREPARE JOB SAFETY ANALYSIS (JSA) TO ASSESS AND CONTROL HAZARDS ASSOCIATED WITH DISMANTLING, TRANSPORT AND STOWING OF PLANT.
142582.14	Flammable substances	ENSURE NO SMOKING AND NO IGNITION SOURCES WITHIN THE VICINITY OF THE PLANT. IN PARTICULAR WHEN FILLING AND OR RE-FUELLING VEHICLES. PROVIDE PPE AS APPLICABLE. FIRE EXTINGUISHER PRESENT ON THIS PLANT.
142582.15	Plant Operation	ACCESS TO BE RESTRICTED TO AUTHORISED AND TRAINED PERSONNEL ONLY. FIT HAZARD WARNING SIGNS (AS APPROPRIATE) TO PREVENT ACCESS TO DANGER ZONES.

# Hazard Register



---

142582.16 Chemicals

ENSURE THAT THE JSA INCLUDES AN ASSESSMENT OF REMOVAL OF RESIDUAL CHEMICALS. REVIEW STORAGE/DISPOSAL, MATERIAL SAFETY DATA SHEETS AND PERSONAL PROTECTIVE EQUIPMENT REQUIREMENTS.

142582.17 warning device

COLLISION WITH PLANT.THERE IS A WARNING STROBE LIGHT ON THIS PLANT. ENSURE THAT THE WARNING LIGHT IS FUNCTIONING PRIOR TO USE IN THE WORKPLACE.

## Health and Safety Plant Safety Purchaser Information

This plant health and safety information has been prepared by Grays for the purchaser of the plant item as required by National WHS Legislation. Whilst every effort has been made to identify all of the hazards, it should be recognised that all reasonably practicable hazards have been identified given due consideration to:

- state of knowledge about the plant item
- the availability and suitability of ways to eliminate or control the hazards
- the cost of evaluating, eliminating or controlling the hazard

Consequently, if this plant item is being purchased for use at a place of work, the purchaser is reminded of their obligations to involve and consult with employees in identifying foreseeable hazards, assess their risks and to take action to eliminate or control the risks.

In order to assess the risk, it is necessary to consider for all the identified hazards, the chance (likelihood) of something happening that would impact (consequence) on health and safety at the workplace. The following guidelines are provided to assist the purchaser in consistently carrying out an assessment of risk:

Likelihood	Consequences
<ul style="list-style-type: none"><li>• Frequency and duration of exposure</li><li>• Probability of occurrence of hazard or event (including part history of incidents)</li><li>• Possibility to avoid / minimize or limit the damage, impact or harm</li><li>• Reliability and effectiveness of existing / established systems of control</li></ul>	<ul style="list-style-type: none"><li>• Assume “worst case” injury, but also competent follow-up medical and rehabilitation support</li><li>• Consider forces or energy levels, highest belt tensions, size of gears, pulleys or other entrapment points and therefore body parts likely to be injured</li><li>• Consider sharpness of entrapment points, surrounding parts likely to exacerbate injury, and any give in the entrapment point</li><li>• Consider, will entrapment continue until plant is stopped, or can an injured part travel through the entrapment area</li><li>• Are temperatures of plant, or chemicals, likely to further injure entrapped person</li></ul>

The outcome of the risk assessment will be a prioritised list of risk control strategies and actions consistent with the following ratings:

Low risk- may be considered acceptable, where the existing controls in place are seen to be effective, requiring periodic monitoring for effectiveness.

Medium risk- considered to be unacceptable and requiring additional risk controls within medium to long term.

High risk – considered to be unacceptable and requiring action within the short to medium term.

Extreme risk – unacceptable, where immediate action required.

In all of these cases employees/operators must be made aware of the risk controls in place to protect them from the hazards.