

Hazard Register



Type	BLOWER	Location	-
Make	-	Sale Number	1967
Model	-	Lot Number	-
Serial Number			

ID	Hazard Type	Hazard Description
143187.1	Plant Operation	ENERGY SOURCES ASSOCIATED WITH THE PLANT (ELECTRICAL ETC.) TO BE ISOLATED WHEN THE PLANT IS BEING DISMANTLED, CLEANED/MAINTAINED. ALL GUARDS REPLACED/FITTED BEFORE THE PLANT IS PUT BACK INTO SERVICE.
143187.2	Electrical	PLANT NEEDS TO BE REGULARLY INSPECTED AND MAINTAINED AS PER AS/NZS3760: IN-SERVICE SAFETY INSPECTION AND TESTING OF ELECTRICAL EQUIPMENT AND AS/NZS3000: WIRING RULES AND/OR AS1543: ELECTRICAL EQUIPMENT OF INDUSTRIAL MACHINES.
143187.3	Noise	SOUND PRESSURE LEVELS NEED TESTING AT OPERATOR STATION. IF SPL GREATER THAN 85 dB(A), NOISE CONTROLS SHOULD BE IMPLEMENTED EG CLEAR & VISIBLE WARNINGS MUST BE ATTACHED RE: USE OF HEARING PROTECTION.
143187.4	Electrical	PLANT TO BE USED WITH AN ELECTRICAL CIRCUIT BREAKER (SAFETY SWITCH) AND OVERLOAD PROTECTION.
143187.5	Skills	PLANT TO BE USED AND ACCESSED BY COMPETENT/SKILLED PERSONEL ONLY.
143187.6	Plant Operation	NO MAINTENANCE OR SERVICE RECORDS AVAILABLE. CONDUCT REGULAR DOCUMENTED SERVICE/INSPECTION OF THE PLANT. MAINTAIN RECORDS OF CHANGES/MODIFICATIONS MADE TO THE PLANT.
143187.7	Plant Structure	STABILITY OF APPLIANCE AND OR ATTACHMENTS TO THE PLANT/APPLIANCE, ENSURE THE PLANT IS SECURELY RESTRAINED/SUPPORTED.
143187.8	Training	PROVIDE ANY MANUFACTURER'S MANUALS/INSTRUCTIONS FOR THE PLANT.
143187.9	Work Space	SLIP/TRIP/FALL DUE TO CLIMATE CONDITIONS. WIPE CLEAR (BEFORE USING THE PLANT) FLOOR, GRIPS, STEPS IF THERE IS ANY MUD, OIL OR OTHER OBSTRUCTIONS ON THE PLANT.
143187.10	PPE	PERSONAL PROTECTIVE EQUIPMENT (PPE) - IDENTIFY TYPE AND PROVIDE INSTRUCTION/INFORMATION RE: USE, STORAGE, CARE AND MAINTENANCE OF PPE (E.G. EYE & HEAR PROTECTION, DUST MASK ETC.)
143187.11	Electrical	ALL OPERATIONAL (AND PROGRAMMABLE) CONTROLS TO BE CLEARLY IDENTIFIED AND LABELLED.
143187.12	Electrical	ALWAYS SWITCH OFF THE POWER AT THE SOURCE BEFORE UNPLUGGING THE PLANT. GRASP THE PLUG FIRMLY, NOT THE CORD / LEAD WHEN UNPLUGGING.
143187.13	Electrical	TO PREVENT FIRE AND ELECTRICAL SHOCKS, DO NOT EXPOSE THE PLANT TO WET ENVIRONMENTS (INCLUDING: AREAS OF HIGH HUMIDITY, SPLASHES OF WATER AND DUSTY LOCATIONS) AND DO NOT HANDLE PLUG OR THE PLANT WITH WET HANDS.
143187.14	Process Manual	SUPPLY MANUFACTURERS OPERATING INSTRUCTIONS (INCLUDING PRE OPERATIONAL CHECKS AND PERSONAL PROTECTIVE EQUIPMENT REQUIRMENTS).
143187.15	Temperature (Thermal Comfort)	EXPOSURE TO OUTDOOR CLIMATE/WEATHER CONDIITONS. ROTATE WORKERS BETWEEN INDOOR/SHADED AND OUTDOOR/EXPOSED LOCATIONS, PROVIDE PERSONAL PROTECTIVE EQUIPMENT (PPE).
143187.16	PPE	PROVIDE INSTRUCTION ON STORAGE, USE, CARE AND MAINTENANCE OF PPE.

Health and Safety Plant Safety Purchaser Information

This plant health and safety information has been prepared by Grays for the purchaser of the plant item as required by National WHS Legislation. Whilst every effort has been made to identify all of the hazards, it should be recognised that all reasonably practicable hazards have been identified given due consideration to:

- state of knowledge about the plant item
- the availability and suitability of ways to eliminate or control the hazards
- the cost of evaluating, eliminating or controlling the hazard

Consequently, if this plant item is being purchased for use at a place of work, the purchaser is reminded of their obligations to involve and consult with employees in identifying foreseeable hazards, assess their risks and to take action to eliminate or control the risks.

In order to assess the risk, it is necessary to consider for all the identified hazards, the chance (likelihood) of something happening that would impact (consequence) on health and safety at the workplace. The following guidelines are provided to assist the purchaser in consistently carrying out an assessment of risk:

Likelihood	Consequences
<ul style="list-style-type: none">• Frequency and duration of exposure• Probability of occurrence of hazard or event (including part history of incidents)• Possibility to avoid / minimize or limit the damage, impact or harm• Reliability and effectiveness of existing / established systems of control	<ul style="list-style-type: none">• Assume “worst case” injury, but also competent follow-up medical and rehabilitation support• Consider forces or energy levels, highest belt tensions, size of gears, pulleys or other entrapment points and therefore body parts likely to be injured• Consider sharpness of entrapment points, surrounding parts likely to exacerbate injury, and any give in the entrapment point• Consider, will entrapment continue until plant is stopped, or can an injured part travel through the entrapment area• Are temperatures of plant, or chemicals, likely to further injure entrapped person

The outcome of the risk assessment will be a prioritised list of risk control strategies and actions consistent with the following ratings:

Low risk- may be considered acceptable, where the existing controls in place are seen to be effective, requiring periodic monitoring for effectiveness.

Medium risk- considered to be unacceptable and requiring additional risk controls within medium to long term.

High risk – considered to be unacceptable and requiring action within the short to medium term.

Extreme risk – unacceptable, where immediate action required.

In all of these cases employees/operators must be made aware of the risk controls in place to protect them from the hazards.