

TRANSCARE LABORATORY GATE 3 GROVE AVE (PO Box 660) MARLESTON SA 5033 Ph: (08) 8152 0092

05/09/24

Fax: (08) 8234 2442



Accreditation Number 11727

## Certificate of Analysis (for insulating oil only)

:	5/09/2024	
:	Auspower HVPS	
:	Not stated	
:	0414 482 256	
er Number:	Not stated	
	John Arthur	
1:	05/09/24	Date Tested :
	: : er Number:	: Auspower HVPS Not stated : 0414 482 256 er Number: Not stated John Arthur

Test method used: Internal test method TM 160

Lab ID #	Location	Manufacturer	Transformer Name/ Equipment Number	Serial Number	PCB Total (mg/kg)
24090071	23000lt Storage Tank	23000lt Storage Tank	Storage Tank	РСВ	<2

## Comments:

1. In case of Transcare was responsible for collection of these samples, this sampling activity is not covered by NATA accreditation

2. Limit of detection 0.4mg/kg.

3. A result of <2 Positive indicates PCB's were detected but were below 2 mg/kg.

4. The estimated uncertainty of measurement (including sampling process) for these test results are  $\pm 20\%$ 

5. This certificate supercedes all previous issued reports of same number by the issue date.

6. All information is supplied by customer, except for the results.

Copies:-

Transcare File

Accredited for compliance with ISO/IEC 17025-Testing This report shall not be reproduced except in full.

Authorised by:

Cere

Hiep Quach Authorised Signatory