

**GENERATOR LOAD TEST REPORT**

**GENERATOR CHANGEOVER TEST**

WO / JOB NO: ..... DATE: 01/05/2026  
 ENGINE TYPE: Perkins 1103A-33TG2 ..... SERIAL NO: DK51280\*U222878T  
 ALTERNATOR TYPE: Stamford ..... SERIAL NO: X09K430730  
 SET SIZE / MODEL: Gesan 60kVA Prime Power ..... SERIAL NO: 269350  
 CLIENT: .....

Time	Load (KW)	Eng Hrs	Voltage			Amps			HZ	Eng Temp °C	Oil Pres PSI/ KPA	Oil Temp °C	Ambient Temp/ Smoke Level °C
			U	V	W	U	V	W					
11.00	24	No Meter	415	415	415	30	27	27	49	70	No Meter	86.6	24.4
11.10	36	No Meter	415	415	415	47	47	48	49	76	No Meter	92.2	24.4
11.20	48	No Meter	415	415	415	65	63	64	48.9	81	No Meter	99.9	24.4
11.30	48	No Meter	415	415	415	65	63	64	48.9	85	No Meter	100.2	24.4
11.40	48	No Meter	415	415	415	65	63	64	48.9	87	No Meter	103.8	24.6
11.50	48	No Meter	415	415	415	65	63	64	48.9	87	No Meter	104.2	24.8
12.00	12	No Meter	415	415	415	16	14	14	49	80	No Meter	95.2	24.8

COMMENTS: Generator performed well under full load conditions.  
 .....  
 .....  
 .....  
 .....  
 .....  
 .....

TESTED BY: J.B. ..... SIGNED 01/05/26 .....